

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220267

Product: PQ monitor

Type: MEg38/C

Rating: Power supply: 55-460 V AC, max. 16 VA
Measuring: 300 V AC, CAT IV/460 V AC, CAT III, Safety class II, IP65

Ordering firm: MEgA - Měřicí Energetické Aparáty, a.s.
Česká 390, 664 31 Česká, Czech Republic

Manufacturer: MEgA - Měřicí Energetické Aparáty, a.s.
Česká 390, 664 31 Česká, Czech Republic

Factories: MEgA - Měřicí Energetické Aparáty, a.s.
Česká 390, 664 31 Česká, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 220666-01/01 of: 26.05.2022, 220666-01/02 of: 26.05.2022

A sample of the product was found to be in conformity with:
ČSN EN 61010-1 ed. 2:2011+A1:2019,
ČSN EN 61010-2-030:2011

Other data:

The validity of the certificate is limited to: 29.05.2025

30.05.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



220666-01