

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1240456

**Product:** PQ monitor

**Type:** MEg45DIN

**Rating:** Supply from measuring lines L1, L2 and L3 or 10 -30 V DC  
Measuring: 3 x 300 V (L1, L2, L3 + N), CAT IV  
Currents: 5A/1A, CAT II

**Ordering firm:** MEgA - Měřicí Energetické Aparáty, a.s.  
Česká 390, 664 31 Česká, Czech Republic

**Manufacturer:** MEgA - Měřicí Energetické Aparáty, a.s.  
Česká 390, 664 31 Česká, Czech Republic

**Factories:** MEgA - Měřicí Energetické Aparáty, a.s.  
Česká 390, 664 31 Česká, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 240533-01/01 of: 11.09.2024, 240533-01/02 of: 11.09.2024

A sample of the product was found to be in conformity with:  
ČSN EN 61010-1 ed. 2:11+A1:19, ČSN EN 61010-2-030 ed. 2:21+A11:21

**Other data:**

The validity of the certificate is limited to: 23.09.2027

24.09.2024

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



240533-01